

MINIATURE NEEDLE PRINTER 57 MM FOR USING TOGETHER WITH REM 370 ANALYSER

The miniature matrix printer MDI 57 is designed for using together with the REM370 power supply analyser. It enables the generation of printouts reporting the recorder state and the measurements performed by this device. The above information can be obtained at the object, without the need for stopping measurements and their registration in the memory, or de-mounting the registering device from the installation.



The printer can print out the wide range of measurement reports, namely:

- Report from measurement of supply voltage parameters at the angle of the conformity with EN 50160 standard or with the standard defined by the user, consisting on defining other threshold values.
- Report from measurement of momentary values including:
 - Values of : voltages U , currents I , active powers P , reactive powers Q , distortion powers D , apparent powers S .
 - Values of : active power factor PF , power tangents tg , distortion power factor DF .
 - Values of : voltage shape coefficients CFU and current shape coefficients CFI for particular phases $L1$, $L2$ and $L3$ and for three-phase system $THDU$ and $THDI$ depending on the analyser configuration.
 - Values of voltage symmetrical components : zero-sequence component $U0$, positive-sequence component $U1$, negative-sequence component $U2$ and their ratio $U2/U1$.
 - Value of zero-sequence cable current $I0$.
 - Values of phase-to-phase voltages $U12$, $U23$, $U31$.
 - Values of peak average summary powers : active Pav , reactive Qav , apparent Sav .
 - Values of energy: active taken $Ep+$ and delivered $Ep-$, reactive taken $Eq+$ and delivered $Eq-$, and apparent Es .
- Report from measurement of momentary harmonics (up to 24) including:
 - Values of voltages $UH0$ and currents $IH0$ for direct component.
 - Values of voltages $UH1$ and currents $IH1$ for basic component.
 - Values of percent content for higher voltage harmonics $UH2$ $UH24$ in relation to basic component or to rms value, depending on configuration.
 - Values of percent content for higher current harmonics $IH2$ $IH24$ in relation to basic component or to rms value, depending on configuration.
- Bar chart of harmonics content for one of the parameters U_{L1} , U_{L2} , U_{L3} , I_{L1} , I_{L2} , I_{L3} selected before the printout.
- Report of values for energy counters including:
 - Values of energy : active taken $Ep+$ and delivered $Ep-$, reactive taken $Eq+$ and delivered $Eq-$, and apparent Es .
- Graphs of oscillations for one of the parameters U_{L1} , U_{L2} , U_{L3} , I_{L1} , I_{L2} , I_{L3} selected before the printout.
- Indicating mark's diagrams of voltages and currents.

Technical specification

Number of text columns 40
 Number of graphic columns 211
 Characters Matrix 5x7
 Printout speed 1,5 of row per second
 Interface RS232 Optical
 Paper width 57 mm
 Maximum paper roll diameter 50 mm
 Supply voltage 230 VAC, +10%, -15%, 50 Hz
 Environmental conditions:


Ambient temperature 0C - 40C
 Relative humidity 5% - 80%
 (without water vapor condensation)
 165 x 141 x 110 mm
 810 g

Dimensions
 Weight


REN-370 nr D01/2002 ver.2.0 swiazda
 Data i czas wydruku: 02-05-17 14:18:09
 Pomiary wykonano w stacji numer 2
 Stacja 2

Napiecie znamionowe Un[V] 230
 Przekładniki:
 napieciomoe[V/V] 230.0 / 230
 pradowe[A/V] 200.0 / 1.00

KSZTALT PRZEBIEGU U11



KSZTALT PRZEBIEGU I11



REN-370 nr D01/2002 ver.2.0 swiazda
 Data i czas wydruku: 02-05-17 14:17:15
 Pomiary wykonano w stacji numer 2
 Stacja 2

Napiecie znamionowe Un[V] 230
 Przekładniki:
 napieciomoe[V/V] 230.0 / 230
 pradowe[A/V] 200.0 / 1.00

POMIARY CHWILOWE f[Hz]= 50.0

	L1	L2	L3	TOTAL
U[V]	237	236	236	409
I[A]	2.63	4.41m	8.55m	1.53
P[W]	316	27.3m	63.8m	316
Q[Var]	400	25.1m	258m	400
Qc[Var]	241	1.04	2.00	244
Sc[VA]	623	1.04	2.02	624
PF	0.40	0.02	0.03	0.50
ts	1.52	0.91	4.04	1.52
DF	0.38	0.99	0.99	0.39
CFU[%]	9.69%	97.6%	97.6%	
CFI[%]	121%	192%	148%	

POZOSTALE POMIARY

U1[U]= 235 U12[U]= 2.06
 U1U= 310m U23[U]= 3.70
 U2U= 400m U31U= 3.64
 U2/U1[%]= 76.0%
 I1[A]= 2.63
 Ep+= 0.000000k
 Ep-= 0.000000k
 EpW[] = 000 Ep+= 0.000000k
 Qav[Var]= 000 Ep+= 0.000000k
 Sav[VA] = 000 Es-= 0.000000k
 Es = 0.000000k

Exemplary printouts (Polish language version) of measured momentary values and curves of current and voltage of phase 1.

Exemplary printout (Polish language version) of report from power supply voltage measurements performed for checking its conformity with EN 50 160 standard:

```

-----
REM-370 nr 001/2301                               gwiazda
Data i czas wydruku: 30-10-02 13:08:12
Pomiary wykonano w stacji numer 1
Kalisz, ul.Kusocinskiego 54. stacja
pomiarowa wschodnia
Napiecie znamionowe Un[V] 15.0k
Przekladniki:
napieciowe[V/V] 15000.0 / 10.0m
pradowe[A/V] 1000.0 / 1.00
-----
RAPORT ZGODNOSCI Z NORMA: PN-EN 50160

POMIARY ROZPOCZETO: 01-01-99 12:23:00
POMIARY ZAKONCZONO: 07-01-99 12:23:00
CZAS USREDNIANIA: 10 min.
POMIAROW ZEBRANO: N= 1080
-----
* - oznacza niezgodnosc wyników z norma
-----
- CZESTOTLIWOSC NAPIECIA SIECI
WYNIKI:
50.0Hz-1.00%+1.00% 96%N (min. 95%N)
* 50.0Hz-6.00%+4.00% 99%N (min. 100%N)
-----
- NAPIECIE ZASILAJACE

Un 10.0%+10.0% przez min. 95%N
z pominięciem przerw U<=1.00%Un
WYNIKI:
-----
L1 | L2 | L3
-----
* * 91%N | 96%N | * 95%N
-----
- NIESYMETRIA NAPIECIA ZASILAJACEGO

U1/U2<=2.00% przez min. 95% czasu N
gdzie: U1-skladowa symetryczna
kolejnosci zgodnej
U2-skladowa symetryczna
kolejnosci przeciwniej
* WYNIK: * 90%N
-----
- HARMONICZNE NAPIECIA ZASILAJACEGO

Srednie wart. skut. poszczegolnych
harmonicznych musza byc <= od podanych
ponizej wartosci progowych przez 95%
czasu wszystkich pomiarow N.
WYNIKI:
-----
wartosc | wzgl. czas pomiaru:
zadana |
progowa | L1 | L2 | L3
-----
* H2<=2.0%H1 | * 92%N | 96%N | * 97%N
H3<=2.0%H1 | 96%N | 96%N | 97%N
H4<=2.0%H1 | 92%N | 96%N | * 97%N
H5<=2.0%H1 | 92%N | 96%N | * 97%N
H6<=2.0%H1 | 92%N | 96%N | * 97%N
H7<=2.0%H1 | 92%N | 96%N | * 97%N
H8<=2.0%H1 | 92%N | 96%N | * 97%N
H9<=2.0%H1 | 92%N | 96%N | * 97%N
* H10<=2.0%H1 | 92%N | 96%N | * 97%N
H11<=2.0%H1 | 92%N | 96%N | * 97%N
H12<=2.0%H1 | 92%N | 96%N | * 97%N
H13<=2.0%H1 | 92%N | 96%N | * 97%N
H14<=2.0%H1 | 92%N | 96%N | * 97%N
H15<=2.0%H1 | 92%N | 96%N | * 97%N
H16<=2.0%H1 | 92%N | 96%N | * 97%N
H17<=2.0%H1 | 92%N | 96%N | * 97%N
* H18<=2.0%H1 | 92%N | 96%N | * 97%N
H19<=2.0%H1 | 92%N | 96%N | * 97%N
H20<=2.0%H1 | 92%N | 96%N | * 97%N
H21<=2.0%H1 | 92%N | 96%N | * 97%N
H22<=2.0%H1 | 92%N | 96%N | * 97%N
H23<=2.0%H1 | 92%N | 96%N | * 97%N
H24<=2.0%H1 | 92%N | 96%N | * 97%N
-----
THD<=8.00% | 92%N | 96%N | * 97%N
-----
gdzie: H1 - srednia wartosc skuteczna
podstawowej harmonicznej
THD - liczony wzgledem H1
    
```

Configuration of recorder used for measurement

Information on collected measurements and time of averaging

Examination results of frequency fluctuations

Examination results of average rms voltage value

Examination results of average value for asymmetry voltage

Examination results of averaged contents for particular harmonics

Examination results of averaged total harmonics distortion coefficient

```

=====
DODATKOWE WYNIKI STATYSTYCZNE: ? - oznacza
ilosc wieksza niz 60000
-----
-- NA PODSTAWIE TABELI POMIAROW RMS
TWORZONYCH CO OKRES USREDNIANIA:
- PRZERWY W ZASILANIU Ilosc rekordow w
ktorych
Umin lub Ustr < 1.00%*Un
-----
dla | L1 | L2 | L3
-----
Umin | 12346 | 23456 | 13456
Ustr | 3 | 3 | 1
-----
- ZAPADY NAPIECIA
Ilosc rekordow w ktorych
Umin lub Ustr < Un-10.0%
-----
dla | L1 | L2 | L3
-----
Umin | 13456 | 23456 | 12345
Ustr | 3 | 3 | 1
-----
Najwieksza glebokosc zapadu z wszystkich
wybranych uprzednio rekordow
-----
dla | L1 | L2 | L3
-----
Umin | -12.3% | -60.1% | -23.4%
Ustr | -12.3% | -60.1% | -23.4%
-----
- PRZEPIECIA DORYWCZE
Ilosc rekordow w ktorych
Umax lub Ustr > Un+10.0%
-----
dla | L1 | L2 | L3
-----
Umax | 12356 | 12356 | 12356
Ustr | 3 | 3 | 1
-----
Najwieksze przepiecie z wszystkich
wybranych uprzednio rekordow
-----
dla | L1 | L2 | L3
-----
Umax | +12.3% | +60.1% | +23.4%
Ustr | +12.3% | +60.1% | +23.4%
-----
-- NA PODSTAWIE TABELI PRZERW I PRZEPIEC
-----
- PRZERWY W ZASILANIU
Ilosc przerw dla ktorych U<ok. 1.0%*Un
-----
czas przerwy t | L1 | L2 | L3
-----
t<1sek. | 60000? | 900 | 100
1sek.<=t<3min. | 1 | 60000? | 60000?
t>=3min. | 1 | 0 | 0
-----
- PRZEPIECIA PRZEJSCIOWE
Ilosc sekund, w ktorych wystapily
przepiecia o amplitudzie
U(t) > 1.41*(Un+90.6%)
-----
| L1 | L2 | L3
-----
ilosc sekund | 1 | 0 | 2
-----
Parametry krytyczne przepiec
-----
| L1 | L2 | L3
-----
czas# [ms/s] | 1000 | 1000 | 1000
amplituda [V] | 548 | 485 | 800
-----
# -maksymalny, lacznny czas przekroczenia
przebiegu chwilowego powyzej
ustawionego progu, wybrany z kazdej
sekundy
    
```

Information on number of measurement records, in which breaks have been detected

Information on number of measurement records, in which drops of voltage have been detected and parameters of critical drops of voltage

Information on number of measurement records, in which overvoltages have been detected and parameters of critical overvoltages

Information on number of breaks in supply with their classification according to their duration

Information on short overvoltages (from 1,2 ms duration) which occurred during examination

signature